

HYDRANT PRESSURE TESTS		
	Apr-16	
HYDRANT NUMBERS	LOCATION	PSI
101	829 SMITH CRESENT	80
102	1214 SECOND STREET	76
103	FIRE HALL	
105	501 12TH AVE	60
106	305 12TH AVE	60
107	413 14TH AVE	55
108	611 16TH AVE	112
109	805 SMITH CRESENT	75
110	537 14TH AVE	65
111	507 15TH AVE	63
112	960 PINE CRESENT	68
113	935 TAMARACK CRESENT	70
114	110 12TH AVE	75
115	537 12TH AVE	65
116	1785 HOMEGOODS RD	112
117	603 17TH AVE	100
118	360 GRANDVIEW PLACE	80
119	605 COURTESY RD	87
120	1055 COURTESY RD	85
121	915 HOMEGOODS RD	65
122	813 16TH AVE	80
123	141 WEEKS RD	60
124	513 13TH AVE	65
125	517 14TH AVE	57
126	102 12TH AVE	73
127	310 15TH AVE	62
128	1008 COMMERCIAL WAY	90
129	1010 COMMERCIAL WAY	95
130	329 12TH AVE	90
131	1204 2ND AVE	75
132	1175 LOWER CHINA CK	75

133

1035 LOWER CHINA CK

65